

Water Testing Procedures

- Action level for copper is greater than 1.300 mg/L
- Action level for lead is greater than 0.015 mg/L
- Locations are required to be tested /mandated by the state requirements
- Schools whose plumbing is new or has been renovated after December 31, 1990 are exempt, as are schools that already monitor lead. Schools constructed on or before December 31, 1960, must test by June 30, 2021. Those constructed between January 1, 1961 and December 31, 1990 must test by June 30, 2022.

Private Wells

- Private wells for schools are as follows
 - Morgan Elementary
 - Bostian Elementary
 - Knollwood Elementary
 - Enochville Elementary
 - Millbridge Elementary
 - Mt. Ulla Elementary
- Well schools are required to be checked every day that school is in session.
 - This check is for Chlorine, PH level and water usage.
- Every quarter the well schools are required to be tested for bacteria.
- Locations are required to be tested, mandated by the state requirements.

Copper /Lead Testing

- A Copper / Lead test sample is taken from a faucet at the location, early in the morning when the water has been in the line with no flow, for at least 6 hours, from the furthest location away from the supply.
- All samples will be processed by a State Certified Facility